

Address: _____ Permit #: _____ Date: _____

ELECTRICAL FINAL CHECKLIST

General:

YES	NO	N/A	
___	___	___	1. All fixtures must be listed and suitable for location used.
___	___	___	2. Incandescent closet fixtures must be globe type and installed 12" horizontally from the edge of shelf.
___	___	___	3. All conductive parts grounded. Watch for metallic pipe between plastic "LB's"
___	___	___	4. Must have a switched light or receptacle in each habitable room.
___	___	___	5. Switched light at outdoor entrance.
___	___	___	6. Bell transformers accessible (Not installed inside electrical panels or attics).
___	___	___	7. All 120V, 15-20-amp receptacles shall be listed tamper resistant.
___	___	___	8. All 120V, 15-20-amp branch circuits in kitchens, family rooms, dining rooms, living rooms, parlors, Libraries, dens, bedrooms, sunrooms, recreation rooms, closets, hallways, laundry areas, or similar rooms or areas shall be AFCI protected.
___	___	___	9. A totally enclosed weatherproof outlet cover – weatherproof when card attached on all 15-20 AMP 1 120-250 Volt receptacles installed in wet locations. Receptacles installed in wet locations.
___	___	___	10. All 15-20 AMP / 120-250 Volt non-locking receptacles installed in damp or wet locations must be listed Weather resistant type.
___	___	___	11. Smoke detectors (and carbon monoxide detectors when required) are in proper locations and installed Per manufacturers requirements.

Enclosures:

___	___	___	1. Panel labeled with electrician's name and address. All circuits identified and spare breakers must be Marked accordingly.
___	___	___	2. Open knockouts sealed.
___	___	___	3. All covers and plates installed.
___	___	___	4. All switches and receptacles grounded.
___	___	___	5. If metal conduit is used to protect service entrance conductors, a bonding bushing must be used if the largest concentric or eccentric knockout has not been punched out.
___	___	___	6. Return plans to original location, sign and date permit card, or leave correction notice with items listed.

THESE GUIDELINES ARE NOT ALL INCLUSIVE. ADDITIONAL REQUIREMENTS IN THE FLORIDA BUILDING CODE MAY ALSO APPLY TO YOUR PROJECT. IF YOU NEED FURTHER ASSISTANCE, PLEASE CONSULT THE CURRENT BUILDING CODE. IF YOU HAVE ANY FURTHER QUESTIONS, PLEASE CONTACT THE CITY OF INVERNESS COMMUNITY DEVELOPMENT DEPARTMENT AT 352-726-3401 OR DDS@INVERNESS.GOV.