

Address: _____ Permit #: _____ Date: _____

IRRIGATION INSPECTION CHECKLIST

YES	NO	N/A	
___	___	___	1. Is the irrigation permitted?
___	___	___	2. A shut off valve must be installed in the supply line to the system.
___	___	___	3. Check for rain sensor and timer or manual zone valves.
___	___	___	4. Proper backflow prevention must be provided.
___	___	___	a. Atmospheric type vacuum breaker installed downstream of the zone valves and above The highest sprinkler head per manufacturer's installation instructions.
___	___	___	b. Pressure type vacuum breaker: may be installed upstream of the zone valves and And above the highest head per manufacturer's instructions.
___	___	___	c. Reduced pressure principle zone (RPZ) backflow preventer – required when chemicals are introduced into the system.
___	___	___	d. All irrigation heads shall be a minimum of 12" away from the building exterior wall.
___	___	___	5. Reclaimed irrigation.
___	___	___	a. Is the irrigation permitted?
___	___	___	b. All piping to be marked by the industry standard color purple from factory.
___	___	___	c. All irrigation heads to be marked for reuse from factory.
___	___	___	d. All valve boxes to be marked for reuse from factory.
___	___	___	6. Retro-fit system.
___	___	___	a. New service line from reuse meter to point of connection with the existing irrigation Piping or any other new irrigation piping shall be the industry standard color Purple from the manufacturer.
___	___	___	b. Piping, connections shall be left uncovered for inspection.
___	___	___	c. All exposed existing piping, irrigation heads and valve boxes shall be retrofitted, Changed to the industry standard color purple, with manufactured piping, Irrigation heads and valve boxes.
___	___	___	d. Any connections disconnected from a potable source shall be left open for inspection.

THESE GUIDELINES ARE NOT ALL INCLUSIVE. ADDITIONAL REQUIREMENTS IN THE FLORIDA BUILDING CODE MAY ALSO APPLY TO YOUR PROJECT. IF YOU NEED FURTHER ASSISTANCE, PLEASE CONSULT THE CURRENT BUILDING CODE. IF YOU HAVE ANY FURTHER QUESTIONS, PLEASE CONTACT THE CITY OF INVERNESS COMMUNITY DEVELOPMENT DEPARTMENT AT 352-726-3401 OR DDS@INVERNESS.GOV.